



## Guidelines on signal list

### Technical regulation 3.2.2 for PV power plants with a power output above 11 kW

0	Published UK edition	27.11.2014	27.11.2014	27.11.2014	27.11.2014	DATE
REV.	DESCRIPTION	KDJ	XLOC	BJA	TSK	NAME
		PREPARED	CHECKED	REVIEWED	APPROVED	
		14/17997-32				

## Revision view

Section no.	Text	Revision	Date
	New document – registered with the Danish Energy Regulatory Authority	0	27.11.2014

## Table of contents

Revision view.....	2
Table of contents.....	3
Reading instructions .....	4
1. Terminology and definitions .....	5
2. Signal list .....	5
3. The signal names of SUNSPEC Alliance .....	5

## Reading instructions

These guidelines have been prepared as an aid for understanding a few more details concerning the required signals for all *photovoltaic (PV) power plant categories* with which the *plants* must be able to exchange on the *PCOM* interface in order to be connected to the grid in Denmark.

In the document, references are made to the *plant* requirements and section 7 in TR 3.2.2.

These guidelines have been prepared by Energinet.dk and are available at [www.energinet.dk](http://www.energinet.dk).

## 1. Terminology and definitions

General terms and definitions which are referred to in TR 3.2.2, section 1, are used in this document.

## 2. Signal list

Information, metering signals and activation possibilities are specified in TR 3.2.2, section 7. In the chart below, a few more details and explanations regarding the individual signals have been described with respect to the use of the information. The information must be available at the *PCOM* interface for the *plant*.

Activation of the individual functions in the *plants* and the configuration of the specific parameters must comply with the requirements specified in TR 5.8.1.

The signal list has been prepared in Excel file format and is available at [www.energinet.dk](http://www.energinet.dk).

## 3. The signal names of SUNSPEC Alliance

In the chart below, the individual signals have been mentioned with reference to the signal names of SUNSPEC Alliance wherever it has been possible.

# Signal list for PV Power Plants - TF 3.2.2

Revision: 1.0 date: 19.11.2014															
Specifications for sunspec profiles are available for download at: www.sunspec.org/download. The specifications can be downloaded free of charge by entering name and affiliation. Subsequently, the documentation can be seen in the zip file at the following website address: (Protocol-Information-Conformance-Statements.zip) (Protocol Information Conformance Statements)															
Category															
A	B	C	D	Signal description	Comments	Possible interval	Typical value	Unit	Data types	Purpose of the signal	Responsible for signal availability in PCOM	Ancillary services	Energynet.dk reference	Model Prefix Abbreviations	Start Offset
	X	X	X	Switch gear status in POC		Open/closed	-	-	Status	Monitor coupling state network for netPOC	Network owner		TR 5.8.1	IC123	5
	X	X	X	Active power kW - metered in POC	Active power metering	0 - P <sub>max</sub>	-	kW	Metering	Input for settlement	Meter operator		TR 5.8.1	M203	19
		X	X	Active power control - ramp rate constraint	Active power control	Active/Inactive	-	-	Control	Activation/deactivation function	Plant owner	Mandatory ancillary services	TR 5.9.1	Always active	
		X	X	Active power control - gradient for upward active power control	Active power control	10 - 300 kW/WTGS/s	50 kW/WTGS/s	kW/second	Set point	Speed control for upward regulation of active power	Plant owner	Mandatory ancillary services	TR 5.9.1	IC123	9
		X	X	Active power control - ramp rate for downward active power control	Active power control	10 - 300 kW/WTGS/s	50 kW/WTGS/s	kW/second	Set point	Control the speed for downward regulation of active power	Plant owner	Mandatory ancillary services	TR 5.9.1	IC123	9
		X	X	Active power control - absolute power constraint	Active power control	Active/Inactive	-	-	Control	Activation/deactivation function	Plant owner	Mandatory ancillary services	TR 5.9.1	Always active	
		X	X	Active power control - desired maximum active power	Active power regulation	0 - P <sub>max</sub>	-	kW	Set point	Input for controlling active power supplied from a PV power plant	Plant owner	Mandatory ancillary services	TR 5.9.1	IC123	6
		X	X	Active power control - delta power constraint	Active power regulation	Active/Inactive	-	-	Control	Activation/deactivation function	Plant owner	Mandatory ancillary services	TR 5.8.1 + tender documents	N.A.	
		X	X	Active power control - desired regulating reserve - P <sub>delta</sub>	Frequency control	0 - P <sub>max</sub>	-	kW	Set point	Input for creating reserves of active power in a PV power plant	Plant owner	Mandatory ancillary services	TR 5.8.1 + tender documents	N.A.	
	X	X	X	Reactive power Mvar - metered in POC	Reactive power control	Q <sub>min</sub> to Q <sub>max</sub>	-	kvar	Metering	Input for active power controlling	Meter operator		TR 5.8.1	M203	29
		X	X	Power factor - metered in POC	Reactive power control	0 - 1	-	-	Metering	Input for reactive power controlling	Plant owner	Mandatory ancillary services	TR 5.9.1	M203	34
		X	X	Power factor - desired PF in POC	Reactive power control	0 - 1	1	-	Set point	Set points for desired power factor	Plant owner	Mandatory ancillary services	TR 5.9.1	IC123	11
		X	X	Reactive power control - active/not active	Reactive power control	Active/Inactive	-	-	Control	Activation/deactivation function	Plant owner	Mandatory ancillary services	TR 5.9.1	IC123	23
		X	X	Reactive power control - desired reactive power in POC	Reactive power control	Q <sub>min</sub> to Q <sub>max</sub>	0	kvar	Set point	Set point for desired Mvar	Plant owner	Mandatory ancillary services	TR 5.9.1	IC123	17
		X	X	Voltage - voltage metered in the voltage reference point	Voltage control	V <sub>refmin</sub> - V <sub>refmax</sub>	-	V	Metering	Input for voltage control in POC	Meter operator	Optional ancillary services	TR 5.8.1 + tender documents	M203	12
		X	X	Voltage control - activated/not activated	Voltage control	Active/Inactive	-	-	Control	Activation/deactivation function	Plant owner	Optional ancillary services	TR 3.2.2 + tender documents	IC126	4
		X	X	Voltage control - voltage metered in POC	Voltage control	U <sub>min</sub> to U <sub>max</sub>	-	V	Metering	Monitor voltage condition in a PV power plant	Plant owner	Optional ancillary services	TR 3.2.2 + tender documents	M203	12
		X	X	Voltage control - droop for voltage control	Voltage control	2 - 6%	4%	% of U <sub>n</sub>	Set point	Droops for voltage stabilisation in POC	Plant owner	Optional ancillary services	TR 3.2.2 + tender documents	N.A.	
		X	X	Voltage control - desired voltage in voltage reference point	Voltage control	U <sub>ref</sub> ± 10%	-	V	Set point	Input for voltage stabilisation in POC	Plant owner	Optional ancillary services	TR 3.2.2 + tender documents	N.A.	
		X	X	Frequency response - activated/not activated	Frequency response	Active/Inactive	-	Hz	Set point	Activation/deactivation function	Plant owner	Optional ancillary services	TR 5.8.1 + tender documents	IC134	4
		X	X	Frequency response - start frequency for frequency response - f <sub>ref</sub>	Frequency response	50.00 - 50.50	50.2	Hz	Set point	Input for frequency stabilisation	Plant owner	Optional ancillary services	TR 5.8.1 + tender documents	IC134	14-53
		X	X	Frequency control - frequency metered in POC	Frequency control	47.00 - 52.00	-	-	Status	Input for frequency stabilisation in POC	Meter operator		TR 5.8.1	M203	17
		X	X	Frequency control - activated/not activated	Frequency control	Active/Inactive	-	-	Status	Activation/deactivation function	Plant owner	Mandatory ancillary services	TR 5.9.1	N.A.	
		X	X	Reference frequency - desired frequency in POC - f <sub>ref</sub>	Frequency control	50.00	50.00	Hz	Set point	Input for frequency stabilisation in POC	Plant owner	Mandatory ancillary services	TR 5.9.1	N.A.	
		X	X	Frequency control - control limit - low - f <sub>min</sub>	Frequency control	46.50 - 47.50	47.00	Hz	Set point	Lower control limit value for frequency control	Plant owner	Mandatory ancillary services	TR 5.9.1	N.A.	
		X	X	Frequency control - control limit - high - f <sub>max</sub>	Frequency control	51.00 - 52.50	52.00	Hz	Set point	Upper control limit value for frequency control	Plant owner	Mandatory ancillary services	TR 5.9.1	N.A.	
		X	X	Frequency control - start frequency for regulation band and frequency response - f <sub>1</sub>	Frequency control	49.50 - 50.00	49.80 or 50.20	Hz	Set point	Input for frequency stabilisation in POC	Plant owner	Optional ancillary services	TR 5.8.1 + tender documents	N.A.	
		X	X	Frequency control - start frequency for dead band - f <sub>2</sub>	Frequency control	49.80 - 50.00	49.88	Hz	Set point	Input for frequency stabilisation in POC	Plant owner	Optional ancillary services	TR 5.8.1 + tender documents	N.A.	
		X	X	Frequency control - end frequency for dead band - f <sub>3</sub>	Frequency control	50.00 - 50.20	50.02	Hz	Set point	Input for frequency stabilisation in POC	Plant owner	Optional ancillary services	TR 5.8.1 + tender documents	N.A.	
		X	X	Frequency control - end frequency for regulation band - f <sub>4</sub>	Frequency control	50.00 - 50.50	50.2	Hz	Set point	Input for frequency stabilisation in POC	Plant owner	Optional ancillary services	TR 5.8.1 + tender documents	N.A.	
		X	X	Frequency control - end frequency for regulation up to f <sub>5</sub>	Frequency control	51.00 - 52.00	51.25	Hz	Set point	Input for frequency stabilisation in POC	Plant owner	Optional ancillary services	TR 5.9.1	N.A.	
		X	X	Frequency control - end frequency for regulation up to f <sub>6</sub>	Frequency control	51.00 - 52.00	51.75	Hz	Set point	Input for frequency stabilisation in POC	Plant owner	Optional ancillary services	TR 5.9.1	N.A.	
		X	X	Frequency control - droop 1 for regulation from f <sub>1</sub> to f <sub>2</sub>	Frequency control	2 - 8%	4%	% of P <sub>n</sub>	Set point	Input for frequency stabilisation in POC	Plant owner	Optional ancillary services	TR 5.8.1 + tender documents	N.A.	
		X	X	Frequency control - droop 2 for regulation from f <sub>3</sub> to f <sub>4</sub>	Frequency control	2 - 8%	6%	% of P <sub>n</sub>	Set point	Input for frequency stabilisation in POC	Plant owner	Optional ancillary services	TR 5.8.1 + tender documents	N.A.	
		X	X	Frequency control - droop 3 for regulation from f <sub>4</sub> to f <sub>5</sub>	Frequency control	2 - 10%	8%	% of P <sub>n</sub>	Set point	Input for frequency stabilisation in POC	Plant owner	Mandatory ancillary services	TR 5.9.1	N.A.	
		X	X	Frequency control - droop 4 for downward regulation from f <sub>5</sub> to f <sub>6</sub>	Frequency control	5 - 20%	10%	% of P <sub>n</sub>	Set point	Input for frequency stabilisation in POC	Plant owner	Mandatory ancillary services	TR 5.9.1	N.A.	
		X	X	Frequency control - frequency limit, for reclosure, if active power has been reduced to below P <sub>min</sub> - f <sub>7</sub>	Frequency control	50.00 - 50.10	50.05	Hz	Set point	Input for frequency stabilisation in POC	Plant owner	Mandatory ancillary services	TR 5.9.1	N.A.	
		X	X	System protection	System protection	Active/Inactive	-	-	Control	Activation/deactivation function	Plant owner	Mandatory ancillary services	TR 5.9.1	IC123	6
X	X	X	X	Stop signal	System protection	Active/Inactive	-	-	Control	Activation/deactivation of plant	Plant owner	Mandatory ancillary services	TR 5.9.1	IC123	5
X	X	X	X	On-hold signal - "Released for start"	System protection	Active/Inactive	-	-	Control	Activation/deactivation of start of plant	Plant owner	Mandatory ancillary services	TR 5.9.1	IC123	5