

#### **ENERGINET**

Energinet Tonne Kjærsvej 65 DK-7000 Fredericia

+45 70 10 22 44 info@energinet.dk CVR no. 28 98 06 71

# APPENDIX 1 DOCUMENTATION TECHNICAL REGULATION 3.3.1 FOR ELECTRICAL ENERGY STORAGE FACILITIES

**EFFECTIVE FROM 18 December 2019** 

Please note: This is a translation. In case of inconsistencies, the Danish version applies.

#### Appendix 1 Documentation

Appendix 1 specifies the documentation requirements for the five facility categories, see section 1.1.4:

- A. Energy storage facilities up to 125 kW
- B. Energy storage facilities from and including 125 kW up to 3 MW
- C. Energy storage facilities from and including 3 MW up to 25 MW
- D. Energy storage facilities from and including 25 MW or connected at voltages above 100 kV  $\,$
- SX. Category A or B energy storage facilities
- T. Temporarily connected energy storage facilities

Documentation, see specifications in section 9, must be sent electronically to the electricity supply undertaking.

The technical documentation must include configuration parameters and configuration data applicable to the energy storage facility at the time of commissioning.

All appendix subsections must be filled in for the facility in question.

If information changes after the time of commissioning, updated documentation must be submitted as required in section 2.2.

Templates for Appendix 1 for the various facility categories are available on Energinet's website <a href="https://www.energinet.dk">www.energinet.dk</a>.

# Contents Appendix 1

Documentation – category A	4
B1.1. Documentation for category A energy storage facilities	
B1.2. Documentation for category A energy storage facilities	7
Documentation – category B	12
B1.3. Documentation for category B energy storage facilities (Part 1)	12
B1.4. Documentation for category B energy storage facilities (part 2)	19
Documentation – categories C and D	22
B1.5. Documentation for category C and D energy storage facilities (part 1)	
B1.6. Documentation for category C and D energy storage facilities (part 2)	29
Documentation – category Sx	33
B1.7. Documentation for category Sx energy storage facilities	
Documentation – category T	34
B1.8. Documentation for category T energy storage facilities	

# Documentation – category A

#### Documentation for category A energy storage facilities

Documentation must be filled in with data for the energy storage facility and sent to the electricity supply undertaking.

d	ler	J,	ti	ti	Ca	ıti	or	١
	a	dei	den	denti	dentifi	dentifica	dentificati	dentificatior

bi.i.i. identification	
Facility	Description of the facility
GSRN no.	
Facility owner name and address	
Facility owner telephone no.	
Facility owner e-mail	
Inverter – manufacture	
Inverter – model	
Inverter – rated power	
Storage medium – manufacture	
Storage medium – model no.	
Storage medium –	
usable energy storage capacity [kWh]	
P1 1 2 Positive list	

#### B1.1.2. Positive list

Only applies to facilities up to 50 kW.

Is the energy storage facility on the positive list?	Yes
If No, B1.2. must also be filled in.	NO 🔲

#### B1.1.3. Active power control

B1.1.3.	Active power control	
Is the frequency	response function for overfrequency activated?	Yes No
If Yes, with whic Frequency thres Droop: Time for island o	_	Hz % ms
	Reactive power control Power factor control	
Is the power fac	tor control function activated?	Yes No No
If Yes, with whic (Value differing supply undertak	from cosφ 1.0 must be agreed with the electricity	cosф Inductive ☐ Capacitive ☐
B1.1.4.2.	Automatic power factor control	
	power factor control function activated?  ated without agreement with the electricity supply	Yes No
Point 2 – P/Pn Point 2 – Power Point 3 – P/Pn	h set points?  factor (inductive)  factor (inductive)  factor (inductive)	% % cosф % cosф
B1.1.4.3.	Q control	
Is the Q control	function activated?	Yes No
If Yes, with whic (Value differing by ply undertaking.	from 0 kVAr must be agreed with the electricity sup-	kVAr

#### B1.1.5. Protection

#### B1.1.5.1. Relay settings

Please state current values at the time of commissioning in the table below.

Protective function	Symbol	Setting	Trip time
Overvoltage (step 2)	U>>	V	ms
Overvoltage (step 1)	U>	V	S
Undervoltage (step 1)	U<	V	S
Undervoltage (step 2)*	U<<	V	ms
Overfrequency	f>	Hz	ms
Underfrequency	f<	Hz	ms
Change of frequency*	df/dt	Hz/s	ms

<sup>\*</sup> At least one of the functions must be activated.

#### B1.1.6. Signature

Date of commissioning	
Installation contractor	
Person responsible for	
commissioning	
Signature	
(person responsible for	
commissioning)	
Facility owner	
Signature (facility owner)	

#### B1.2. Documentation for category A energy storage facilities

Documentation must be filled in with data for the energy storage facility to be included on the positive list, or if the facility is not on the positive list.

#### B1.2.1. Identification

Facility	Description of the facility	
Facility owner name and address		
radiney owner hame and dadress		
Facility owner telephone no.		
Facility owner e-mail		
Inverter – manufacture		
Inverter – model		
Inverter – rated power		
Storage medium – manufacture		
Storage medium – model no.		
Storage medium –		
usable energy storage capacity [kWh]		
B1.2.2. Normal operation		
Can the facility be started and operate contin		Yes 🗌
tion range, restricted only by protective settin 7?	ngs, c.f. requirements in section	No
Where to find documentation that this requir	ement has been met?	

#### B1.2.3. Tolerance of frequency deviations

Will the energy storage facility remain connected to the public electricity supply grid during frequency deviations as specified in section 4?	Yes No
Where to find documentation that this requirement has been met?	
Will the facility remain connected in the event of frequency changes of 2.0 Hz/s in the POC?	Yes No
If Yes, reference to documentation:	
B1.2.4. Start-up and automatic reclosing of an energy storage facility	
Does start-up and automatic reclosing occur after three minutes following voltage and frequency coming within the areas specified in section 4.3.1?	Yes No
Where to find documentation that this requirement has been met?	
Please state how each power quality parameter result was achieved.	
B1.2.5.1. Rapid voltage changes	
Does the energy storage facility comply with the rapid voltage changes threshold specified in section 5.1.1.3?	Yes No
Where to find documentation that this requirement has been met?	
B1.2.5.2. DC content	
Does DC content at normal operation exceed 0.5% of rated current?	Yes  No
Where to find documentation that this requirement has been met?	

#### B1.2.5.3. Current imbalance

Does the current imbalance at normal operation exceed 16 A?	Yes  No
Where to find documentation that this requirement has been met?	
If the facility is made up of single-phase energy storage units, have measures been taken to ensure that the above threshold is not exceeded?	Yes  No
Where to find documentation that this requirement has been met?	
B1.2.5.4. Flicker	
Is the flicker contribution for the entire facility below the threshold specified in section 5.1.1.4?	Yes No
Where to find documentation that this requirement has been met?	
B1.2.5.5. Harmonics	
Are all harmonics for the entire facility below the thresholds specified in section 5.1.1.5?	Yes No
Where to find documentation that this requirement has been met?	
B1.2.5.6. Interharmonics  This part must only be filled in for energy storage facilities larger than 50 kW.	
Are all interharmonics for the entire energy storage facility below the thresholds specified in section 5.1.1.6?	Yes
Where to find documentation that this requirement has been met?	
	1

#### B1.2.5.7. Disturbances in the 2-9 kHz range

This part must only be filled in for energy storage facilities larger than 50 kW	This part must	only be filled	in for energy	storage facilities	larger than 50 kW.
--	----------------	----------------	---------------	--------------------	--------------------

	1	
Is the emission of disturbances with frequencies in the 2-9 kHz range lower than 0.2% of rated current $I_n$ as required in section $\frac{5.1.1.7}{?}$ ?	Yes 🗌 No 🔲	
Where to find documentation that this requirement has been met?		
B1.2.6. Control functions B1.2.6.1. Active power control B1.2.6.1.1. Frequency response at overfrequency		
Is the energy storage facility equipped with a frequency response function in cas overfrequency?	se of	Yes
B1.2.6.1.2. Absolute power constraint		
Is the energy storage facility equipped with an absolute power constraint function	on?	Yes  No  No
B1.2.6.1.3. Ramp rate constraint function		
Is the energy storage facility equipped with a ramp rate constraint function?		Yes  No
B1.2.6.2. Reactive power control B1.2.6.2.1. Work area		
Can the energy storage facility supply reactive power at $P_n$ and varying operating voltages, as specified in section 6.3?		Yes No No
Where to find documentation that this requirement has been met?		
Can the energy storage facility supply reactive power at varying active power as specified in section 6.3?		Yes No No
Where to find documentation that this requirement has been met?		

#### B1.2.6.2.2. Power factor control

Is the energy storage facility equipped with a power factor control function as specified in sections 6.3.2 and 6.3.2.1?	Yes No
B1.2.6.2.3. Automatic power factor control	
Is the energy storage facility equipped with automatic power factor control as specified in sections 6.3.4 and 6.3.4.1?	Yes  No
B1.2.6.2.4. Q control	
Is the energy storage facility equipped with a Q control function as specified in sections 6.3.1 and 6.3.1.1?	Yes No

#### B1.2.7. Protection against electricity system faults

#### B1.2.7.1. Relay settings

The table below lists default values for relay settings. If default values deviate from the values specified in section 7.2.1, documentation must be provided to ensure that relay settings can be set to the correct values upon commissioning.

Protective function	Symbol	Setting	Trip time
Overvoltage (step 2)	U>>	V	ms
Overvoltage (step 1)	U>	V	S
Undervoltage (step 1)	U<	V	S
Undervoltage (step 2)	U<<	V	ms
Overfrequency	f>	Hz	ms
Underfrequency	f<	Hz	ms
Frequency change	df/dt	Hz/s	ms

#### B1.2.8. Signature

Date	
Company	
Person responsible for	
commissioning	
Signature	
(person responsible for	
commissioning)	
Facility owner	
Signature (facility owner)	

# Documentation – category B

#### B1.3. Documentation for category B energy storage facilities (Part 1)

Please fill in the documentation form with data for the facility, valid before commissioning, and submit it to the electricity supply undertaking.

#### B1.3.1. Identification

Facility	Description of the facility	
Facility owner name and address		
Facility owner telephone no.		
Facility owner e-mail		
Inverter – manufacture		
Inverter – model		
Inverter – rated power		
Storage medium – manufacture		
Storage medium – model no.		
Storage medium –		
usable energy storage capacity [kWh]		
B1.3.2. Normal operation		
DI.3.2. Normal operation	1	
Can the energy storage facility be started and	operate continuously within the	Yes 🗌
normal operation range, restricted only by gri		No $\square$
quirements in section Figure 6?	,	
•		
If Yes, reference to documentation:		

#### B1.3.3. Tolerance of frequency deviations

Will the energy storage facility remain connected to the public electricity supply grid during frequency deviations as specified in section 4?	Yes No
If Yes, reference to documentation:	
Will the facility remain connected in the event of frequency changes of 2.0 Hz/s in the POC?	Yes No
If Yes, reference to documentation:	
B1.3.4. Tolerance of voltage deviations (FRT)	
Will the energy storage facility remain connected to the public electricity supply grid during voltage dips as specified in section 4.4?	Yes No
If Yes, reference to documentation:	
Will the energy storage facility remain connected to the public electricity supply grid during voltage increases as specified in section 4.4?	Yes No No
If Yes, reference to documentation:	
After a voltage dip, the energy storage facility is able to return to normal operation no later than 5 s after operating conditions have returned to the normal operating range.	Yes No
B1.3.5. Additional reactive current	
Does the energy storage facility deliver additional reactive current as specified in section 4.4.4?	Yes No
If Yes, reference to documentation:	

# Start-up and automatic reclosing of an energy storage facility B1.3.6.

Do connection and synchronisation occur as specified in section 4.3.1?  If Yes, reference to documentation:	Yes No No
Is it possible to circumvent automatic synchronisation?  If No, reference to documentation:	Yes No
B1.3.7. Active power control B1.3.7.1. Frequency Response – Overfrequency	
Is the energy storage facility equipped with a frequency response function for overfrequency as specified in section 6.2.2.1?  If Yes, reference to documentation:	Yes
B1.3.7.2. Absolute power constraint function	
Is the energy storage facility equipped with an absolute power constraint function as specified in section 6.2.4.1.1?  If Yes, reference to documentation:	Yes 🗌 No 🗍
B1.3.7.3. Ramp rate limit	
Is the energy storage facility equipped with a ramp rate constraint as specified in section 6.2.4.2.1?  If Yes, reference to documentation:	Yes No No

#### B1.3.8. Reactive power control

#### B1.3.8.1. Work area

Can the energy storage facility supply reactive power at $P_n$ and varying of ating voltages, as specified in section 6.3?	per- Yes 🗍 No 🗍	
Where to find documentation that this requirement has been met?		
Can the energy storage facility supply reactive power at varying active po as specified in section 6.3.5.2?	ower Yes No No	
Where to find documentation that this requirement has been met?		
B1.3.8.2. Power factor control		
Is the energy storage facility equipped with a power factor control functi as specified in section 6.3.2.1?	ion Yes No	
If Yes, reference to documentation:		
B1.3.8.3. Q control		
Is the energy storage facility equipped with a Q control function as specified in section 6.3.1.1?		
If Yes, reference to documentation:		
B1.3.8.4. Automatic power factor control		
Is the automatic power factor control function activated? (Not to be activated without agreement with the electricity supply undertaking.)	Yes No	
If Yes, with which set points?%  Point 1 – P/Pncosф  Point 1 – Power factor (inductive)		
Point 1 – Power factor (inductive)  Point 2 – P/Pn  Point 2 – Power factor (inductive)  Point 3 – P/Pn		
Point 3 – P/Pn  Point 3 – Power factor (inductive)  cos		

#### B1.3.9. Power quality

, ,	
Are stated emission values calculated values?	Yes 🗌 No 🗍
Are stated emission values measured values?	Yes 🗌 No 🗍
Is a report enclosed, documenting that calculations or measurements comply with emission requirements?  If Yes, reference to documentation:	Yes No
B1.3.9.1. Rapid voltage changes	
Does the energy storage facility comply with the threshold for rapid voltage changes specified in section 5.1.1.3?	Yes No
If Yes, reference to documentation:	
B1.3.9.2. DC content	
Does DC content at normal operation exceed 0.5% of rated current?	Yes No No
If Yes, reference to documentation:	
B1.3.9.3. Voltage unbalance	
Is the facility three-phase balanced?	Yes No No
If Yes, reference to documentation:	140
	1

B1.3.9.4.	Flicker	
	ontribution for the entire energy storage facility below the ified in section 5.1.1.4?	Yes 🗌 No 🗌
If Yes, referenc	re to documentation:	
B1.3.9.5.	Harmonics	
specified in sec		Yes 🗌 No 🗌
If Yes, reference	e to documentation:	
B1.3.9.6.	Interharmonics	
	monics for the entire energy storage facility below the threshnacetion 5.1.1.6?	Yes  No
If Yes, referenc	ee to documentation:	
B1.3.9.7.	Disturbances in the 2-9 kHz range	
	of disturbances with frequencies in the 2-9 kHz range lower as required in section 5.1.1.7?	Yes 🗌 No 🗍
If Yes, reference	re to documentation:	
B1.3.10.	Protection	
	rotected with the functions required in section 7.2.2?	Yes  No
If Yes, referenc	re to documentation:	

# B1.3.10.1. Island operation detection Is the facility protected with the functions required in section 7.2.2? If Yes, reference to documentation: B1.3.11. Information exchange requirements Can the facility exchange information as required in section 8.2? If Yes, reference to documentation:

#### B1.3.12. Signature

Date	
Installation contractor	
Person responsible for commissioning	
Signature (person responsible for commissioning)	
Facility owner	
Signature (facility owner)	

#### B1.4. Documentation for category B energy storage facilities (part 2)

Please fill in the documentation form with data for the energy storage facility, valid after commissioning, and submit it to the electricity supply undertaking.

B1.4.1.	Identification
D1.7.1.	iuciiuiicatioii

Facility	Description of the facility
Facility owner name and address	
Facility owner telephone no.	
Facility owner e-mail	
Inverter – manufacture	
Inverter – model	
Inverter – rated power	
Storage medium – manufacture	
Storage medium – model no.	
Storage medium –	
usable energy storage capacity [kWh]	

#### B1.4.2. Active power control

#### B1.4.2.1. Active power control at overfrequency

Is the frequency response function for overfrequency activated?	Yes No No
If Yes, with which settings?	
Frequency threshold (f <sub>2</sub> ):	Hz
Droop:	%
Time for island operation detection (minimum response time):	ms

B1.4.2.2.	Absolute power constraint function			
Is the absolute	e power constraint function activated?	Online	Yes No control	
If Yes, with wh	nich value?		kW	
B1.4.2.3.	Ramp rate limit		T	
Is the energy	storage facility's ramp rate constraint activated?		Online con	Yes _ No _ itrol _
If Yes, with wh	nich value?		%	P <sub>n</sub> /mir
B1.4.3. B1.4.3.1.	Reactive power control Q control			
Is the Q contr	ol function activated?	Online	Yes No control	
	nich set point? ng from 0 kVAr must be agreed with the electricity sup- ng.)		kVAr	
B1.4.3.2.	Power factor control	1		
Is the power f	factor control function activated?	Online	Yes No control	
	nich set point? ng from cosφ 1.0 must be agreed with the electricity aking.)		cosф ductive [	

#### B1.4.4. Protection

#### B1.4.4.1. Relay settings

Please state current values at the time of commissioning in the table below.

Protective function	Symbol	Setting	Trip time
Overvoltage (step 2)	U>>	V	ms
Overvoltage (step 1)	U>	V	S
Undervoltage (step 1)	U<	V	S
Overfrequency	f>	Hz	ms
Underfrequency	f<	Hz	ms
Change of frequency*	df/dt	Hz/s	ms

<sup>\*</sup> Used for island operational detection in the distribution grid

#### B1.4.5. Signature

Date	
Installation contractor	
Person responsible for	
commissioning	
Signature (person responsible	
for commissioning)	
Facility owner	
Signature (facility owner)	

# $\label{eq:Documentation} \textbf{--} \textbf{categories} \ \textbf{C} \ \textbf{and} \ \textbf{D}$

#### B1.5. Documentation for category C and D energy storage facilities (part 1)

Please fill in the documentation form with data for the facility, valid before commissioning, and submit it to the electricity supply undertaking.

#### B1.5.1. Identification

Facility	Description of the facility	
Facility owner name and address		
Facility owner telephone no.		
Facility owner e-mail		
Inverter – manufacture		
Inverter – model		
Inverter – rated power		
Storage medium – manufacture		
Storage medium – model no.		
Storage medium – usable energy storage		
capacity [kWh]		
B1.5.2. Normal operating conditions		
		$\Box$
Can the energy storage facility be started and		Yes
normal operation range, restricted only by grid protection settings, c.f. re-		No 🗌
quirements in Figure 6-Figure 10?		

#### B1.5.3. Tolerance of frequency deviations

Will the energy storage facility remain connected to the public electricity supply grid during frequency deviations as specified in section 4 for categories C and D?	Yes No No	
Will the facility remain connected in the event of frequency changes of 2.0 Hz/s in the POC?	Yes No No	
B1.5.4. Tolerance of voltage deviations (FRT)		
Will the energy storage facility remain connected to the public electricity supply grid at the voltage dips, as specified in <b>Fejl! Henvisningskilde ikke fundet</b> . and <b>Fejl! Henvisningskilde ikke fundet</b> . for categories C and D, respectively?	Yes  \ No  \	
After a voltage dip, the energy storage facility is able to return to normal operation no later than 5 s after operating conditions have returned to the normal operating range.		
B1.5.4.1. Additional reactive current		
Does the energy storage facility deliver additional reactive current as specified in sections 4.4.4 or 4.4.5 for categories C and D, respectively?	Yes No No	
B1.5.5. Connection and synchronisation		
Do connection and synchronisation occur as specified in section 4.3.1 for categories C and D?	Yes No No	
B1.5.6. Active power control B1.5.6.1. Active power control at overfrequency		
Is the energy storage facility equipped with a frequency response function for overfrequency as specified in section 6.2.2.1 for categories C and D?		

# B1.5.6.2. Active power control at underfrequency Is the energy storage facility equipped with a frequency response function for Yes 🗌 underfrequency as specified in section 6.2.2.3Fejl! Henvisningskilde ikke fun-No 🗌 det. for categories C and D? If Yes, reference to documentation: B1.5.6.3. Frequency control Is the energy storage facility equipped with a frequency control function as Yes specified in section 6.2.3.2 for categories C and D? No $\square$ If Yes, reference to documentation: B1.5.6.4. System protection Is the energy storage facility equipped with a system protection function as Yes specified in section 6.4.2? No 🗌 If Yes, reference to documentation: B1.5.6.5. Absolute power constraint function Is the energy storage facility equipped with an absolute power constraint Yes function as specified in section 6.2.4.1.1 for categories C and D? No $\square$ If Yes, reference to documentation:

#### B1.5.6.6. Ramp rate constraint function

Is the energy storage facility equipped with a ramp power constraint function as specified in section 6.2.4.2.1 for categories C and D?

If Yes, reference to documentation:

#### B1.5.7. Reactive power control functions

#### B1.5.7.1. Requirements for reactive power control area

Can the facility supply reactive power at $P_n$ and varying operating voltages, as specified in sections 6.3.5.3, 6.3.5.4 and 6.3.5.5 for categories C, D and D*, respectively?	Yes
Can the energy storage facility supply reactive power at varying active power as specified in sections 6.3.5.3, 6.3.5.4 and 6.3.5.5 for categories C, D and D, respectively?	Yes
B1.5.7.2. Q control	
Is the energy storage facility equipped with a Q control function as specified in section 6.3.1.1 for categories C and D?	Yes No No
B1.5.7.3. Power factor control	
Is the energy storage facility equipped with a power factor control function as specified in section 6.3.2.1 for categories C and D?	Yes  No
B1.5.7.4. Voltage control	
Is the energy storage facility equipped with a voltage control function as specified in section 6.3.3.2 for categories C and D?	Yes No
Where is the voltage reference point located?	
B1.5.8. Power quality	
Are stated emission values calculated values?	Yes 🗌 No 🗌
Are stated emission values measured values?	Yes No
Is a report enclosed, documenting that calculations or measurements comply with emission requirements?	Yes No

B1.5.8.1.	Rapid voltage changes	
thresholds spe	gy storage facility comply with the rapid voltage changes cified in sections 5.2.1.3 and 5.3 for categories C and D distribuns and category D* transmission connections, respectively?	Yes No
B1.5.8.2.	DC content	
tions 5.2.1.1 ar	nt at normal operation exceed the thresholds set out in sec- nd 5.3 for categories C and D distribution connections and cate- nission connections, respectively?	Yes 🗌 No 🗍
B1.5.8.3.	Voltage unbalance	
Is the facility th	nree-phase balanced?	Yes 🗌 No 🗍
B1.5.8.4.	Flicker	
out in sections	bution for the energy storage facility below the thresholds set 5.2.1.4 and 5.3 for categories C and D distribution connections transmission connections, respectively?	Yes No
B1.5.8.5.	Harmonics	
olds set out in	sections for the energy storage facility below the thresh- sections 5.2.1.5 and 5.3 for categories C and D distribution and category D* transmission connections, respectively?	Yes No No
B1.5.8.6.	Interharmonics	
out in sections	rmonics for the energy storage facility below the thresholds set 5.2.1.6 and 5.3 for categories C and D distribution connections o* transmission connections, respectively?	Yes 🗌 No 🗍
B1.5.8.7.	Disturbances in the 2-9 kHz range	
	stortions with frequencies in the 2-9 kHz range is determined by supply undertaking. Is the requirement met?	Yes No

B1.5.9.	Protection	
	otected with the functions required in sections 7.2.3 and 7.2.4 and D, respectively?	Yes No No
B1.5.9.1.	Island operation detection	
Is the facility progories C and D?	otected with the functions required in section 6.2.3.2 for cate-	Yes No No
B1.5.10. B1.5.10.1.	Information exchange Data communication	
	munication protocols and data security factors been s specified in section 8.2?	Yes
Are signals as sp	pecified in section 8.2 available in the PCOM inter-	Yes
B1.5.10.2. Only for categor	Fault incident recording ry D facilities	
Have logging ed section 8.3 for o	quipment been installed in the POC as specified in category D?	Yes
Has it been agre	eed with the transmission system operator which d be logged?	Yes  No
If 'Yes', which?		
B1.5.11. Simulation model requirements Only for facilities with power output above 10 MW		
Has a simulation	n model been prepared as specified in section ries C and D?	Yes  No
If Yes, reference	e to documentation and model:	

#### B1.5.12. Conformity testing

Has a conformity testing plan been prepared as specified in section 9.2.11 for categories C and D?  If Yes, reference to documentation:		Yes No	
	B1.5.13. Signature	,	
	Date		

Date	
Installation contractor	
Person responsible for	
commissioning	
Signature	
(person responsible for	
commissioning)	
Facility owner	
Signature (facility owner)	

#### B1.6. Documentation for category C and D energy storage facilities (part 2)

Please fill in the documentation form with data for the facility, valid before final commissioning, and submit it to the electricity supply undertaking.

B1.6.1.	Identification

Facility	Description of the facility
GSRN no.	
Facility owner name and address	
Facility owner telephone no.	
Facility owner e-mail	
Inverter – manufacture	
Inverter – model	
Inverter – rated power	
Storage medium – manufacture	
Storage medium – model no.	
Storage medium –	
usable energy storage capacity [kWh]	

#### B1.6.2. Active power control

#### B1.6.2.1. Active power control at overfrequency

Is the frequency response function for overfrequency as specified in section 6.2.2.1 for categories C and D activated?	Yes No
If Yes, with which settings?	
Frequency threshold:	Hz
Droop:	%
Time for island operation detection (minimum response time):	ms

#### B1.6.2.2. Active power control at underfrequency

<u></u>			-
Is the frequency response function for underfrequency as specified in section 6.2.2.3 for categories C and D activated?		Yes No	
If Yes, with which settings? Frequency threshold: Droop: Time for island operation detection (minimum response time):	_ _ _	Hz % ms	
B1.6.2.3. Frequency control	ı		1
Is the frequency control function specified in section 6.2.3.2 for categories C and D activated?	Online	Yes No control	
If Yes, with which settings?  Frequency threshold - Low (f <sub>RU</sub> ):  Frequency threshold - High (f <sub>RO</sub> ):  Droop:  Desired frequency:  ΔP:		Hz Hz % Hz kW	
B1.6.2.4. Absolute power constraint function			
Is the absolute power constraint function as specified in section 6.2.4.1.1 for categories C and D activated?	Online	Yes No control	
If Yes, with which value?		kW	
B1.6.2.5. Ramp rate constraint function		ı	•
Is the energy storage facility's ramp rate constraint function as specified section 6.2.4.2.1 for categories C and D activated?	d in	Online cor	Yes No ntrol
If Yes, with which value?			6P₀/min

#### B1.6.3. Reactive power control

#### B1.6.3.1. Q control

Is the Q control function as specified in section 6.3.1.1 for categories C and D activated?	Yes No Online control
If Yes, with which set point? (Value differing from 0 kVAr must be agreed with the electricity supply undertaking.)	kVAr
B1.6.3.2. Power factor control	
Is the power factor control function as specified in section 6.3.2.1 for categories C and D activated?	Yes No Online control
If Yes, with which set point? (Value differing from cosφ 1.0 must be agreed with the electricity supply undertaking.)	cosф Inductive ☐ Capacitive ☐
B1.6.3.3. Voltage control	
Is the voltage control function as specified in section 6.3.3.2 for categories C and D activated?  (Not to be activated without agreement with the electricity supply undertaking.)	Yes No Online control
If Yes, with which set point?	kV
B1.6.4. Protection	
Has a list of protective functions and settings at the time of commissioning been enclosed?	Yes No
If Yes, reference to documentation:	

B1.6.5.	Conformity testing	
Is documenta	tion of compliance testing enclosed?	Yes No
B1.6.6. Only for facilit	Verification of simulation model ties with power output above 10 MW	
Is the verificat	tion report for the simulation model enclosed	d? Yes ☐ No ☐
B1.6.7.	Signature	
Date		
Installation co	ontractor:	
Person respor	nsible for	
commissionin		
Signature		
(person respo	onsible for	
commissionin	ng)	
Facility owner		
Signature (fac	cility owner)	

# Documentation – category SX

# B1.7. Documentation for category SX energy storage facilities

Documentation must be filled in with data for the energy storage facility and sent to the electricity supply undertaking.

Facility	Description of the facility
GSRN no.	
Facility owner name and address	
Facility owner telephone no.	
Facility owner e-mail	
Inverter – manufacture	
Inverter – model	
Inverter – rated power	
Storage medium – manufacture	
Storage medium – model no.	
Storage medium –	
usable energy storage capacity [kWh]	

#### B1.7.2. Signature

Date of commissioning	
Installation contractor	
Person responsible for commissioning	
Signature (person responsible for commissioning)	
Facility owner	
Signature (facility owner)	

# Documentation – category T

### B1.8. Documentation for category T energy storage facilities

Documentation must be filled in with data for the energy storage facility and sent to the electricity supply undertaking.

B1.8.1. Identification		
Facility	Description of the facility	
GSRN no.		
danni.		
Facility owner name and address		
Facility owner telephone no.		
Facility owner e-mail		
Inverter – manufacture		
Inverter – model		
Inverter – rated power		
Storage medium – manufacture		
Storage medium – model no.		
Charger's rated active power,		
Pnl og Pno [kW]		
M 0.0		
B1.8.2. Normal operation		
Can the energy storage facility be started and	operated continuously within	Yes 🗌
the normal operation range, restricted only by grid protection settings, c.f.		No 🗌
requirements in Figure 5 or Figure 6?		
If Yes, reference to documentation:		
I .		

#### B1.8.3. Tolerance of frequency deviations

Will the energy storage facility remain connected to the public electricity supply grid during frequency deviations as specified in section 4.1?	Yes No
If Yes, reference to documentation:	
Will the facility remain connected in the event of frequency changes of 2.0 Hz/s in the POC?	Yes No
If Yes, reference to documentation:	
B1.8.4. Power quality  Please state how each power quality parameter result was achieved.	
B1.8.4.1. Rapid voltage changes	
B1.8.4.1. Rapid voltage changes  Does the energy storage facility comply with the rapid voltage changes threshold specified in section 5.1.1.3?	Yes No
Does the energy storage facility comply with the rapid voltage changes	
Does the energy storage facility comply with the rapid voltage changes threshold specified in section 5.1.1.3?	
Does the energy storage facility comply with the rapid voltage changes threshold specified in section 5.1.1.3?  Where to find documentation that this requirement has been met?	

#### B1.8.4.3. Current imbalance

Does the current imbalance at normal operation exceed 16 A?	Yes  No
Where to find documentation that this requirement has been met?	
If the facility is made up of single-phase energy storage units, have measures been taken to ensure that the above threshold is not exceeded?	Yes No
Where to find documentation that this requirement has been met?	
B1.8.4.4. Flicker	
Is the flicker contribution for the entire facility below the threshold specified in section 5.1.1.4?	Yes No No
Where to find documentation that this requirement has been met?	
B1.8.4.5. Harmonics	
Are all harmonics for the entire facility below the thresholds specified in section 5.1.1.5?	Yes No
Where to find documentation that this requirement has been met?	
B1.8.4.6. Interharmonics  This part must only be filled in for energy storage facilities larger than 50 kW.	
Are all interharmonics for the entire energy storage facility below the thresholds specified in section 5.1.1.6?	Yes 🗌 No 🗌
Where to find documentation that this requirement has been met?	

#### B1.8.4.7. Disturbances in the 2-9 kHz range

This part must only be filled in for energy storage facilities larger than 50 kW.

Is the emission of disturbances with frequencies in the 2-9 kHz rang than 0.2% of rated current $I_{\text{n}}$ as required in section 5.1.1.7? Where to find documentation that this requirement has been met?	Yes No
B1.8.5. Signature	
Date of commissioning	

Date of commissioning	
Installation contractor	
Person responsible for	
commissioning	
Signature (person responsible	
for commissioning)	
Facility owner	
Signature (facility owner)	